

PROFLOOR Engineered Timber Flooring - By Trojan Timbers

Cone Test

Australian Wool Testing Authority Ltd – trading as AWTA Product Testing

A.B.N 43 006 014 106 1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

Group Number Assessment

(in accordance with AS 5637.1-2015)

This is to confirm that the product as described below has been tested by AWTA Product Testing.

Testing was performed in accordance with AS/NZS 3837-1998 Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter.

Test Sponsor: Trojan Timbers Pty Ltd

PO Box 3363

Stafford DC QLD 4031

Test Number: 17-006425

Issue Date: 27/11/2017 **Print Date**: 27/11/2017

Sponsor Product Clients Ref: "Profloor"

Engineered Timber

End Use: Wall & Ceiling Lining/Flooring Nominal Composition: Engineered Timber Nominal Mass per Unit Area/Density: 640g/m2

Nominal Thickness: 14.2mm

Product Group Number Classification: 3

Average Specific Extinction Area: 33.2 m²/kg

Australian Wool testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025

- Chemical Testing

- Mechanical Testing

- Performance & Approvals Testing

: Accreditation No.

: Accreditation No.

983

Accreditation No.

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

APPROVED SIGNATORY



MICHAEL A. JACKSON B.Sc.(Hons)